



Annex I

No. 2X210115.HCS0D12

Technical Construction File no. SIL-HZKCS-2021-A1

- The use of the product [Actuator] must obey the required rules to maintain the SIL 3 Capable properties. These rules are stated in the Assessment Report, reference No.: [SIL Capability assessment report].
- The product version of hardware components used for assessment are the following:

| Product Type | Model |
|-------------------|--|
| Electric Actuator | HKM.2 Series; HKP.2 Series; HKL.2 Series |

- Assessed documents for the present certification are defined in the Assessment Report [SIL Capability assessment report].
- Acceptable environmental constraints for the system are stated in the safety manual (Ref: [SIL-HZKCS-03]). These elements must be checked for each integration of the product.
- The SIL capable certified of the product is the following:
 - Safety function: move to the designed safe position within the specified safety time.
- The fail rates in FIT (FIT=1 failure/10⁹ hours) is the following:

| Safety Function | Fail safe detected λ_{SD} | Fail safe undetected λ_{SU} | Fail dangerous detected λ_{DD} | Fail dangerous undetected λ_{DU} |
|-----------------|-----------------------------------|-------------------------------------|--|--|
| Stay put | 0 | 125 | 83 | 15 |
| ESD open | 156 | 124 | 75 | 26 |
| ESD close | 206 | 113 | 95 | 37 |

- The safety integrity level (SIL) of the entire Safety Instrument Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.